

H2-47573/22

Municipal Office
Chalakudy, 12/08/22,

SANITARY CERTIFICATE

It is certified that CMI Public School functioning in the building Number XXIV/224, 224 A,B is provided with adequate sanitation and drinking water facilities and found that the sanitation conditions are satisfactory.

This certificate is issued to produce before CBSE, Delhi as per the request from school authorities.

Thanking you


Yours faithfully



Secretary
Health Supervisor
Chalakudy
Municipality

To,

The Principal
CMI Public School
Chalakudy.



True copy



PRINCIPAL
CMI PUBLIC SCHOOL
CHALAKUDY - 680 307
THRISSUR, KERALA, INDIA



FR. URUMEESE MUNDANMANI ANTONY
DIRECTOR
CMI PUBLIC SCHOOL
CHALAKUDY - 680307
THRISSUR - KERALA



Bright water LABORATORY

(Approved By Kerala State Pollution Control Board, Approval No: PCB/CL/RL/133/2021)

VIII / 30 B, First Floor, Potta Ashram Junction, Chalakudy, Thrissur - 680 722
Ph : +91 9605 275 233, info@brightwatertechnologies.com, www.brightwatertechnologies.com

TEST REPORT

Test Report No : BWT/CKDY/LAB/1780/2022

Date of Issue : 16/09/2022

Customer Name & Address : M/s. CMI Public School
Chalakudy

Test Method : As per APHA Method

Date of sample collection : 14/09/2022

Type of sample : Well Water

Date of completion of analysis: 15/09/2022

Sample Drawn by : Self

Sl No.	PARAMETERS	UNIT	ACCEPTABLE LIMIT AS PER IS 10500-1991	RESULTS
PHYSICAL PARAMETERS				
1	pH	-	6.5 -8.5	7.7
2	Colour	Hazen Unit	5	No Color
3	Odour	-	Unobjectionable	Unobjectionable
4	Turbidity	NTU	5	ND
5	Total Dissolved Solids	mg/l	500	110
CHEMICAL PARAMETERS				
6	Chloride	mg/l	250	20
7	Sulphate	mg/l	150	10
8	Alkalinity	mg/l	200	130
9	Total Hardness	mg/l	300	90
10	Calcium	mg/l	75	16.032
11	Magnesium	mg/l	30	11.7
12	Iron	mg/l	0.3	0.3
13	Nitrite	mg/l	-	ND
BACTERIOLOGICAL TEST				
14	Coliform	Coliform /100 ml	Absent	Absent
15	E.coli	E.coli /100 ml	Absent	Absent

Remarks : Satisfactory.

ASST.SCIENTIST

BRIGHT WATER LABORATORY
LAB INCHARGE
ASSIST. SCIENTIST

MICROBIOLOGIST

FOR BRIGHT WATER TECHNOLOGIES

* Authorised Signatory

Note: The test results are valid only for the sample provided. This test report Shall not be reproduced except in full, without the written approval of the laboratory.

ND: Not Detected

TNTC : Too Numerous to Count

True copy
FR. URUMEESE MUNDANMANI ANTONY
DIRECTOR
CMI PUBLIC SCHOOL
CHALAKUDY - 680307
THRISSUR - KERALA

PRINCIPAL
CMI PUBLIC SCHOOL
CHALAKUDY - 680 307
THRISSUR, KERALA, INDIA