


H2-17848/23

Chalakydy Municipality

Dated : 04/10/2023

SANITARY CERTIFICATE

I hereby declare that I have inspected the building and premises of CMI Public School, chalakydy on 03/10/2023 and certified that the accommodation provided is sufficient and is properly ventilated and lighted is kept clean. The latrine arrangements and supply of drinking water are adequate and satisfactory. In all respect the sanitation is good and hygiene.


Secretary/Clean City Manager


Chalakydy Municipality


SECRETARY
CHALAKUDY MUNICIPALITY

To

Principal,
CMI Public School
Chalakydy.


Manager
CMI Public School
Chalakydy, Thrissur Dt.
Kerala, India-680 307



True copy

Principal
CMI Public School
Chalakydy - 680 307
Thrissur, Kerala, India



KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LABORATORY

IRINJALAKUDA, THRISSUR

Telephone No - 0480-2997761, E-mail - kwa.qcsdl.jk@gmail.com

Test Report

Test Report. No.:KWA/QCSDL/IJK-TSR/4890/2023


Report Date : 04.09.2023

Customer Name & Address			1. Date of Receipt : 21.08.2023		
THE PRINCIPAL , CMI PUBLIC SCHOOL , CHALAKUDI , PIN:680307			2. Sampling done by : The Customer		
			3.UID No of Sample:KWA/QCSDL/IJK-TSR/S-004890/23		
			4. Source of Sample : OPENWELL		
			5.Sample condition : Good		
			6.Name of sample : Water		
			7. Sample Quantity : 2 Litre		
			8. Test Performing Dates		
			From : 21.08.2023 To 22.08.2023		
Sl. No.	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500 - 2012	Result
1	Electrical Conductivity	(micro mhos/cm)	IS 3025 (part 14) - 2013 (Reaffirmed 2019) Electrometric method	-	236.60
2	Acidity	(mg/litre)	IS 3025 (part 22) - 1986 (R. 2019) Titration method	-	-
3	Sulphate (as SO ₄)	(mg/litre)	APHA 4500 (SO ₄ ²⁻ E) Turbidity method	200	-
4	Fluoride (as F)	(mg/litre)	APHA 4500 - F ⁻ D Spadns method	1.0	-
5	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) - 2003 (Reaffirmed. 2019) 1,10 Phenanthroline method	1.0	1.61
6	Nitrate (as NO ₃)	(mg/litre)	APHA 4500 - NO ₃ ⁻ B. Ultraviolet screening method	45	1.34
7	Residual Chlorine	(mg/litre)	IS 3025 (part 26) - 1986 (R. 2021) Idometric method	0.2	-

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:




Authorized By:

Quality Manager,
Quality Control Sub District Laboratory
Kerala Water Authority
Irinjalakuda - 680 121

Issue Date 10/01/2023	Issue No:2	KWA/QCSDL/IJK-TSR/R.No:6
Rev.No: 00	Rev Date: 00	Page 1 of 1

Manager
CMI Public School
Chalakudy, Thrissur Dt.
Kerala, India-680 307

True copy
Principal
CMI Public School
Chalakudy - 680 307
Thrissur, Kerala, India



KERALA WATER AUTHORITY
QUALITY CONTROL SUB DISTRICT LABORATORY

IRINJALAKUDA, THRISSUR
Telephone No - 0480-2997761, E-mail - kwa.qcsdl.ijk@gmail.com

Test Report

Test Report. No.:KWA/QCSDL/IJK-TSR/4890/2023


Report Date : 04.09.2023

Customer Name & Address			1. Date of Receipt : 21.08.2023	
THE PRINCIPAL , CMI PUBLIC SCHOOL , CHALAKUDI , PIN:680307			2. Sampling done by : The Customer	
			3. UID No of Sample:KWA/QCSDL/IJK-TSR/S-004890/23	
			4. Source of Sample : OPENWELL	
			5. Sample Condition : Good	
			6. Name of Sample : Water	
			7. Sample Quantity :100ml	
			8. Test Performing Dates	
			From : 21.08.2023	To 22.08.2023
Sl. No.	Parameters	Acceptable limits as per-IS 10500-2012	Test Method	Result
1	Total Coliforms	Shall not be detected / 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	NIL
2	E. Coli	Shall not be detected/ 100ml	IS 15185 : 2016 ISO 9308 - I : 2014	ABSENT

Remarks:-

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by:



Authorized By:

Haritha T.S

Haritha T.S

Quality Manager,
Quality Control Sub District Laboratory
Kerala Water Authority

Issue Date 10/01/2023	Issue No:2	KWA/QCSDL/IJK-TSR/R.No:6
Rev.No: 00	Rev Date: 00	Page 1of 1

Manager

Manager
CMI Public School
Chalakudy, Thrissur Dt.
Kerala India-680 307

True copy

Principal
Principal
CMI Public School
Chalakudy - 680 307
Thrissur, Kerala, India